

**Rocky View Water Co-op Ltd.**

Telephone: **403-239-6242**  
Fax Line: **403-241-3897**

25145 Burma Road  
Calgary, Alberta T3R 1B8

email: [rvwater@rvwater.ca](mailto:rvwater@rvwater.ca)  
web site: [www.rvwater.ca](http://www.rvwater.ca)

**SERVICE CONNECTION SPECIFICATIONS**

**Connection to Curb Stops**

To facilitate connections and avoid damage when excavating at the time of installation, there is a 4 meter length of polyethylene pipe extending from each existing curb stop of which there may be four sizes and types depending upon the property location and time of their construction:

.	*1”	Inside Diameter (Iron Pipe Size)	- Series 160 or Greater	- PHILMAC Fitting
.	*1 ¼”	Outside Diameter (Municipal)	- Series 160 or Greater	- Brass Fitting
.	1 ½”	Outside Diameter (Municipal)	- Series 160 or Greater	- Brass Fitting
.	2”	Outside Diameter (Municipal)	- Series 160 or Greater	- Brass Fitting

(\* Only found on installations prior to 1992-93)

***Do not excavate closer than 4 meters to the curb stop  
&  
Do not remove “red topped” curb valve marker post***

**Installation of Service Line**

Trench Specifications: Not less than 8 ½’ deep.

Waterline Specifications: Minimum 1½” Outside Diameter Series 160 Municipal Tubing CSA Approved for Potable Water.

Fittings Specifications: Brass as per the above.

**Inspection of Workmanship & Materials**

Notify Co-op office at 403-239-6242:

- Before construction to review compliance with the specifications and timing.
- After construction while the tie-in is still exposed for final inspection before the trench is back filled.

*Compliance with these specifications is required to ensure that Co-op members have reliable and durable treated water service lines from the distribution system.  
Members are responsible for any repairs their service lines may require.*

***Thank you for your co-operation***

*Effective January 1, 2010*