

Rocky View Water Co-op Ltd.

Telephone: 403-239-6242
Fax: 403-241-3897

25145 Burma Road
Calgary, Alberta T3R 1B8

email: info@rvwater.ca
web site: www.rvwater.ca

SERVICE CONNECTION SPECIFICATIONS

A Water Service Connection Application must be received by the Co-op at least 48 hours prior to the planned installation. The form can be obtained from the website at www.rvwater.ca or from the office.

Connection to Curb Stops

To facilitate connections and avoid damage when excavating at the time of installation, there should be a 4 meter length of polyethylene pipe extending from each existing curb stop of which there may be four sizes and types depending upon the property location and time of their construction:

- . *1" Inside Diameter (Iron Pipe Size) - Series 160 or Greater - Brass Fitting
- . *1 ¼" Outside Diameter (Municipal) - Series 160 or Greater - Brass Fitting
- . 1 ½" Outside Diameter (Municipal) - Series 160 or Greater - Brass Fitting
- . 2" Outside Diameter (Municipal) - Series 160 or Greater - Brass Fitting

(* Found only on installations prior to 1992-93)

***Do not excavate closer than 4 meters to the curb stop
&
Do not remove the blue or red curb valve marker post***

Installation of Service Line

Trench Specifications: Not less than 8 ½' deep.

Service Line Specifications: Minimum 1½" Outside Diameter Series 160 Municipal Tubing CSA Approved for Potable Water. 2" OD recommended for services >150m from curbstop.

Fittings Specifications: Brass as per the above.

Inspection of Workmanship & Materials

Notify Co-op office at 403-239-6242 following excavation and prior to back fill while the tie-in is still exposed for final inspection.

Compliance with these specifications is required to ensure that Co-op members have reliable and durable treated water service lines from the distribution system. Members are responsible for all damage to RVWC facilities and all repairs their service lines may require.

Thank you for your co-operation